

## Check List for Order Information WRF04LCD 2V

### Display Settings

Standard      Customer's request

ON	<input type="checkbox"/> ON	<input type="checkbox"/> OFF	Display of room temperature
OFF	<input type="checkbox"/> ON	<input type="checkbox"/> OFF	Display of set point temperature
ABSOLUTE	<input type="checkbox"/> ABSOLUTE	<input type="checkbox"/> OFFSET	Display of set point temperature (only type(1))
ABSOLUTE	<input type="checkbox"/> ABSOLUTE	<input type="checkbox"/> OFFSET	Display of set point temp. change (only type(1))
°C	<input type="checkbox"/> °C	<input type="checkbox"/> °F	Unit of temperature to be displayed

### Update Interval Display

Standard	Customer's Request
10s	

### Set point adjustment (optionally, only for visualization (WRF04))

Standard

Customer's Request

Basic set point +/- Offset      ☐ (1) Basic set point +/- Offset      ☐ (2) Fixed range

*(1) Basiscollwert +/- Offset/ Basic Set Point +/- Offset*

Standard

Lower range	Basic value (after Reset)	Upper range Verstellbereich
0 °C	22 °C	0 °C

Customer's request

Minimal value	Basic value (after Reset)	Maximal value

*(2) Fester Bereich/ Fixed Range*

Standard

Lower limit	Upper limit
0 °C	50 °C

Customer's request

Lower limit	Upper limit